

Annual Drinking Water Quality Report for 2025
Village of Brownville - 216 Brown Blvd.
(Public Water Supply ID#22002332)

INTRODUCTION

To comply with State regulations, the Village of Brownville will be annually issuing a report describing the quality of your drinking water. The purpose of this report is to raise your understanding of drinking water and awareness of the need to protect our drinking water sources. Last year, your tap water met all State drinking water health standards. We are proud to report that our system did not violate a maximum contaminant level or any other water quality standard. This report provides an overview of last year's water quality. Included are details about where your water comes from, what it contains, and how it compares to State standards.

If you have any questions about this report or concerning your drinking water, please contact Bill Pickett, DPW Superintendent, 782-7916. We want to be informed about your drinking water. If you want to learn more, please attend any of our regularly scheduled village board meetings. The meetings are held on the second Tuesday monthly at 6:00 P.M. at the Village Offices.

WHERE DOES OUR WATER COME FROM?

In general, the sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activities. Contaminants that may be present in source water include: microbial contaminants; inorganic contaminants; pesticides and herbicides; organic chemical contaminants; and radioactive contaminants. In order to ensure that tap water is safe to drink, the State and the EPA prescribe regulations which limit the amount of certain contaminants in water provided by public water systems. The State Health Departments and FDA's regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Our water system serves 1,650 people through 380 service connections. Our water source is groundwater wells: groundwater drawn from two drilled wells on Washington Street and Cape Vincent water system supplied through the Development Authority of the North Country pipelines. The water is treated with chlorine as well as UV disinfection that is required by the New York State Department of Health prior to distribution.

The New York State Department of Health has completed a source water assessment for this system, based on available information. Possible and actual threats to this drinking water source were evaluated. The state source water assessment includes a susceptibility rating based on the risk posed by each potential source of contamination and how easily contaminants can move through the subsurface to the wells. **The susceptibility rating is an estimate of the potential for contamination of the source water, it does not mean that the water delivered to consumers is or will become contaminated.**

The source water assessment has rated these wells as having a medium-high susceptibility to nitrates, microbial, and halogenated solvents. These ratings are due primarily to potential agricultural practices and a documented hazardous waste site within the well's outer assessment area. The wells draw from fractured bedrock and the overlying soils may not provide adequate protection from potential contamination. The New York State Department of Health will use this information to direct future source water protection activities. A copy of the assessment can be obtained by contacting the supplier of water.

ARE THERE CONTAMINANTS IN OUR DRINKING WATER?

As the State regulations require, we routinely test your drinking water for numerous contaminants. These contaminants include: total coliform, inorganic compounds, nitrate, lead and copper, volatile organic compounds, total trihalomethanes, and synthetic organic compounds. The table presented below depicts which compounds were detected in your drinking water. The state allows us to test for some contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of our data, though representative, are more than one year old.

It should be noted that all drinking water, including bottled drinking water, may be reasonably expected to contain at least some small amounts of contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline (800-426-4791) or the Health Department at 785-2277.

As the State regulations require, we routinely test your drinking water for numerous contaminants. These contaminants include: total coliform, inorganic compounds, nitrate, lead and copper volatile organic compounds, total trihalomethanes, and synthetic organic compounds.

TABLE OF DETECTED CONTAMINANTS							
CONTAMINANT	VIOLATION YES/NO	DATE OF SAMPLE	LEVEL DETECTED (AVG/MAX) (RANGE)	UNIT MEASUREMENT	MCLG	REGULATORY LIMIT (MCL, TT OR AL)	LIKELY SOURCE OF CONTAMINATION
Microbiological Contaminates							
Total Coliform	No	2 samples monthly	ND	n/a	n/a	n/a	Naturally present in the environment.
Inorganic Contaminants							
Barium	No	3/14/25	.054	mg/l	2.0	MCL	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits.
Fluoride	No	3/14/25	0.09	mg/l	4	MCL	Erosion of natural deposits; Water additive which promotes strong teeth.
Lead ¹	No	2023	0.007	mg/l	0.015	MCL	Corrosion of household plumbing systems; Erosion of mineral deposits.
Copper ¹	Yes	2023	1.49	mg/l	1.3	MCL	Corrosion of household plumbing systems; Erosion of mineral deposits.
Nitrate	No	3/14/25	ND	mg/l	10	MCL	
Radiologicals							
Gross Alpha	No	8/18/20	0.75	pCi/L	15.0	MCL	Erosion of natural deposits.
Radium 226	No	8/18/20	0.09	pCi/L	5.0	MCL	Erosion of natural deposits.
Radium 228	No	8/18/20	0.71	pCi/L	5.0	MCL	Erosion of natural deposits.
Disinfection By-Products²							
TTHMs ² (Total Trihalomethanes)	No	2025	34.1	ug/l	80.0	MCL	By-product of drinking water chlorination.
HAA5s ² (Total Haloacetic Acids)	No	2025	4.8	ug/l	60.0	MCL	By-product of drinking water chlorination.
Unregulated Contaminants³							
PFBA	No	8/10/23	5.28	ng/l	10.0	MCL	Released into the environment from widespread use in commercial and industrial applications.

1 – The level presented represents the 90th percentile of the 20 sites tested. A percentile is a value on a scale of 100 that indicates the percentage of a distribution that is equal to or below it. The action level for the 90th copper level was exceeded. The action level for the 90% lead level was not exceeded.

2 – Disinfection by-products are collected quarterly. Compliance is based on the locational running annual average of each sample site. Max and min values in parenthesis.

3 – PFBA is a perfluorinated compound not currently regulated in NYS.

DEFINITIONS:

Maximum Contaminant Level (MCL): The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible.

Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Treatment Technique (TT): A required process intended to reduce the level of a contaminant in drinking water.

Non-Detects (ND): Laboratory analysis indicates that the constituent is not present.

Nephelometric Turbidity Unit (NTU): A measure of the clarity of water. Turbidity in excess of 5 NTU is just noticeable to the average person.

Milligrams per liter (mg/l): Corresponds to one part of liquid in one million parts of liquid (parts per million - ppm).

Micrograms per liter (ug/l): Corresponds to one part of liquid in one billion parts of liquid (parts per billion - ppb).

Nanograms per liter (ng/l): Corresponds to one part of liquid to one trillion parts of liquid (parts per trillion - ppt).

Picocuries per liter (pCi/L): A measure of the radioactivity in water.

Million Fibers per Liter (MFL): A measure of the presence of asbestos fibers that are longer than 10 micrometers.

DO I NEED TO TAKE SPECIAL PRECAUTIONS?

Although our drinking water met or exceeded state and federal regulations, some people may be more vulnerable to disease causing microorganisms or pathogens in drinking water than the general population.

Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice from their health care provider about their drinking water.

EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium, Giardia and other microbial pathogens are available from the Safe Drinking Water Hotline (800-426-4791)

Although our system has an adequate amount of water to meet present and future demands, there are a number of reasons why it is important to conserve water:

- Saving water saves energy and some of the costs associated with both of these necessities of life;
- Saving water reduces the cost of energy required to pump water and the need to construct costly new wells, pumping systems and water towers; and
- Saving water lessens the strain on the water system during a dry spell or drought, helping to avoid severe water use restrictions so that essential firefighting needs are met.

You can play a role in conserving water by becoming conscious of the amount of water your household is using, and by looking for ways to use less whenever you can. It is not hard to conserve water.

Conservation tips include:

- Automatic dishwashers use 15 gallons for every cycle, regardless of how many dishes are loaded. So get a run for your money and load it to capacity.
- Turn off the tap when brushing your teeth.
- Check every faucet in your home for leaks. Just a slow drip can waste 15 to 20 gallons a day. Fix it up and you can save almost 6,000 gallons per year.
- Check your toilets for leaks by putting a few drops of food coloring in the tank, watch for a few minutes to see if the color shows up in the bowl. It is not uncommon to lose up to 100 gallons a day from one of these otherwise, invisible toilet leaks. Fix it and you save more than 30,000 gallons a year.

Thank you for allowing us to continue to provide your family with quality drinking water this year. In order to maintain a safe and dependable water supply we sometimes need to make improvements that will benefit all of our customers. The costs of these improvements may be reflected in the rate structure. Rate adjustments may be necessary in order to address these improvements. We ask that all our customers help us protect our water sources, which are the heart of our community. Please call our office if you have any questions.